

Figure: 25 TAC §265.204(f)

<b>Number of Fixtures at Class A, Class B, and Class C Pools and Spas constructed on or after the effective date of this subchapter.</b>					
Fixture Schedule for Facilities with Water Surface Areas Less than 7500 sq. ft.	Females per 7500 sq. ft.	Males per 7500 sq. ft.	Fixture Schedule for Facilities with Water Surface Areas 7500 sq. ft. or More	Females <sup>1</sup>	Males <sup>1</sup>
Water Closets	1	1	Water Closets	2	0.7
Urinals	NA	1	Urinals	NA	1
Lavatories <sup>2</sup>	1	1	Lavatories <sup>2</sup>	1	0.85
Cleansing showers <sup>3</sup>	1	1	Cleansing Showers <sup>3</sup>	1	1
Rinsing showers <sup>3</sup>	1	1	Rinsing Showers <sup>3</sup>	1	1
Baby Changing Table <sup>4</sup>	1	1	Baby Changing Table <sup>4</sup>	1	1

<sup>1</sup>Number of fixtures per 7500 sq. ft. or portion thereof. Where the result of the fixture calculation is a portion of a whole number, the result shall be rounded up to the nearest whole number.

<sup>2</sup> Lavatories shall be provided with hot and cold running water.

<sup>3</sup>Rinsing showers can be tower showers or single showers without heated water. Not less than one and not more than half of the total number of showers required shall be located on the deck or at the entrance of each pool or spa. Tower rinsing showers are not required to provide heated water.

<sup>4</sup>One for each male or female sanitary facility.